

## KYNDRYL ITALIA SPA

Circonvallazione Idroscalo -20054 SEGRATE (MI)

## **Data Center Site:**

Via Giacomo Peroni, 292 – Tecnopolo Tiburtino – ROMA (RM)

Bureau Veritas Italia SpA –certify that the Data Center of the above organisation has been audited and found to be in accordance with the requirements of the Standard detailed below

## ISO 22237:2018 Part 1-7

Scope of certification

## AS BUILT VALIDATION LEVEL: AVAILABILITY CLASS 4 – PROTECTION SECURITY CLASS 4

KYNDRYL ITALIA SPA DATACENTER ROMA PERONI, FACILITIES AND COMPUTER ROOMS, INCLUDING SITE LOCATION, ARCHITECTURE, SECURITY, SAFETY, FIRE SUPPRESSION, ELECTRICAL, MECHANICAL AND TELECOMMUNICATION.

Original cycle start date: 01 September 2021

Expiry date of previous cycle: 19 June 2022

Recertification Audit date: 26 June 2022

Certification cycle start date: 26 June 2022

Subject to the continued satisfactory operation of the organization's Management System, this certificate expires on: **26 June 2025** 

Certificate No. - Version: IT316920-1 Revision date: 26 June 2022

Giorgio Lanzafame – Llogal Technical Manager

Certification body address:

Bureau Veritas Italia S.p.A., Viale Monza, 347 - 20126 Milano, Italia

Further clarifications regarding the scope of this certificate and the applicability of the management system requirements may be obtained by consulting the organization.



